

Permit Number _____

Date _____

**PIPE BURSTING
SPECIAL APPROVAL AUTHORIZATION**

OWNER: _____

CONTRACTOR: _____

LOCATION: _____

REQUESTED WORK: To repair the existing sewer lateral using a pipe bursting method and inserting high-density polyethylene (HDPE) pipe.

CONDITIONS:

1. Pay applicable fees and secure an encroachment permit prior to beginning work.
2. The Contractor shall furnish, install, and test, complete and in place, HDPE pipe and fittings, in accordance with ANSI/ASTM F 585, Practice for Insertion of Flexible Polyethylene Pipe into Existing Sewers. The Contractor is responsible for selecting an appropriate method for pipe bursting and maintaining line and grade. The pipe shall be SDR 17. Joints shall be made by using the thermal fusion technique per the manufacture recommendation. The Contractor shall allow for thermal contraction or expansion of HDPE pipe prior to connecting each end with fitting.
3. Side sewers that have sags and are flatter than the minimum slope specified by City shall not be pipe burst. The Contractor shall have a camera on site for the inspector to confirm that the side sewer is a candidate for pipe bursting. The inspector's determination is **final**. The Contractor shall perform an internal closed circuit television inspection on the side sewer after completing pipe insertion and connecting pipe, and the Contractor shall make application for witnessing of the television inspection at least twenty-four (24) hours in advance. All work shall conform to City of San Leandro's Standard Plans and Specifications.
4. Owner(s) and Contractor(s) have a mutual understanding that the Contractor(s) must allow a **minimum** of 12 hours of relaxation before final connection to the sewer lateral or sewer main can occur. If necessary, temporary connections can be installed sooner to reinstate sewage flows.
5. The undersigned Contractor(s) and Owner(s) hereby accept and assume **all** liability which may arise from this Special Approval, including, but not limited to: liability for damage to the sewer work on job, damage to City facilities, personal injury, bodily injury and damage to property arising from the construction, ownership, and maintenance of the sewer facilities being constructed, and the property wherein such facilities are to be constructed. Nothing in this Agreement is intended to constitute an admission of liability of the undersigned Contractor or Owner with regard to any third parties or otherwise alter law with regard to liability to third parties.

CONDITIONS ACCEPTED:

Owner: _____
Print Name Signature Date

Contractor: _____
Company Name Signature Date