

Mansfield Fire Department

1305 E. Broad St.
Mansfield, TX 76063
817-276-4790
Fax 817-276-4787



PERMIT APPLICATION

EMERGENCY RESPONDER COMMUNICATION SYSTEM

DATE:	
PROPERTY ADDRESS:	
PROPERTY NAME:	
NEW CONSTRUCTION	Y [] N []
REMODEL	Y [] N []
COMPANY NAME:	
ADDRESS:	
CONTACT PERSON:	PHONE#
EMAIL ADDRESS:	
STATE LICENSE OR CERTIFICATION NUMBER:	

Emergency Responder Communication System

Fee: NO FEE AT THIS TIME

System design shall be based upon 2018 IFC 510 Requirements

Fire alarm system is required to provide monitoring per IFC 510.4.2.5. Separate permit and fee required.

Modifications/additions to building construction and additional fire rated construction requires a building permit through the City of Mansfield Building Safety Department.

Multiple Buildings: Require an application/permit for each building.

See additional requirements on next page.

[SUBMIT PLANS, APPLICATION, SPEC BOOKS, and a COPY OF THE COMPANY COR.](#)

PAYMENT INSTRUCTIONS WILL BE EMAILED TO THE ADDRESS ABOVE

For Fire Department Use Only	
Date Rec'd: _____	Fee Amount: \$ _____
Check #/Card: _____	Receipt #: _____
Permit #: _____	Date Issued: _____
Date Notified: _____	ESO/FH ☐
Permit Type: ☐ Construction	Fire Official Approval _____
☐ Operational	

First Responder Communication System Installation – Page 2

A permit is required on all emergency responder communications installations.

Public Safety Communications projects require a third-party review by a Fire Protection Engineer licensed in the State of Texas prior to submittal to our office. If uncertain about whether a third-party review is needed, you may contact Scott Lingo at 817-276-4770 or scott.lingo@mansfieldtexas.gov

Emergency Responder Communication System is required to be monitored by the building fire alarm system. If a building does not have a fire alarm panel one shall be added to provide required monitoring. Manufacturer and/or distributor proprietary fire alarm equipment is not permitted.

Approved plans shall be maintained on site at all times.

Pre-testing is required prior to requesting an inspection by the Fire Inspector. The alarm report will be requested to verify pre-testing.