

Texas Commission on Environmental Quality
Customer Service Inspection Certificate

Name of PWS:	City of Mont Belvieu
PWS ID #:	0360017
Location of Service:	

Reason for Inspection:	
New construction	☐
Existing service where contaminant hazards are suspected	☐
Material improvement, correction or expansion of distribution facilities	☐

I _____, upon inspection of the private water distribution facilities connected to the aforementioned public water supply do hereby certify that, to the best of my knowledge

Compliance	Non-Compliance		
☐	☐	(1)	No direct or indirect connection between the public drinking water supply and a potential source of contamination exists. Potential sources of contamination are isolated from the public water system by an air gap or an appropriate backflow prevention assembly in accordance with Commission regulations.
☐	☐	(2)	No cross-connection between the public drinking water supply and a private water system exists. Where an actual air gap is not maintained between the public water supply and a private water supply, an approved reduced pressure principle backflow prevention assembly is properly installed.
☐	☐	(3)	No connection exists which would allow the return of water used for condensing, cooling or industrial processes back to the public water supply.
☐	☐	(4)	No pipe or pipe fitting which contains more than 8.0% lead exists in private water distribution facilities installed on or after July 1, 1988 and prior to January 4, 2014
☐	☐	(5)	Plumbing installed on or after January 4, 2014 bears the expected labeling indicating $\leq 0.25\%$ lead content. If not properly labeled, please provide written comment.
☐	☐	(6)	No solder or flux which contains more than 0.2% lead exists in private water distribution facilities installed on or after July 1, 1988

I further certify that the following materials were used in the installation of the private water distribution facilities:

Service lines:	Lead ☐	Copper ☐	PVC ☐	Other ☐
Solder:	Lead ☐	Lead Free ☐	Solvent Weld ☐	Other ☐

Remarks:	

I recognize that this document shall be retained by the aforementioned Public Water System for a minimum of ten years and that I am legally responsible for the validity of the information I have provided.

Signature of Inspector:		License Type:	
Inspector Name(Print/Type):		License Number:	
Title of Inspector:		Date / Time of Insp.:	/

A Customer Service Inspection Certificate should be on file for each connection in a public water system to document compliance with 30 TAC § 290.44(h)/290.46(j).