

Mansfield Fire Rescue

1305 E. Broad St.
Mansfield, TX 76063
817-276-4790
Fax 817-276-4787



PERMIT APPLICATION

SPRINKLER SYSTEM INSTALLATION

DATE:	
PROPERTY ADDRESS:	
PROPERTY NAME:	
NEW CONSTRUCTION	Y [] N []
REMODEL	Y [] N []
COMPANY NAME:	
ADDRESS:	
CONTACT PERSON:	PHONE#
EMAIL ADDRESS:	
STATE LICENSE OR CERTIFICATION NUMBER:	

Sprinkler System Installation

Total # of Heads: _____ # Risers _____

Fee: 1-20 heads \$50.00

21-150 heads \$100.00

151-500 heads \$200.00

501-1000 heads \$300.00 [and, if over 1000 heads, add \$1.00 per head]

SUBMIT PLANS, APPLICATION, SPEC BOOKS, and HYDRAULIC CALCULATIONS.

PAYMENT INSTRUCTIONS WILL BE EMAILED TO THE ADDRESS ABOVE

For Fire Department Use Only

Date Rec'd: _____ Fee Amount: \$ _____ Check #/Card: _____ Receipt #: _____

Permit #: _____ Date Issued: _____ Date Notified: _____ ESO/FH ☐

Permit Type: ☐ Construction
☐ Operational

Fire Official Approval _____

Sprinkler System Installation – Page 2

A permit is required for each new or add-on installation except as outlined herein. If the installation is a new one, a private fire line permit will also be needed. Permit fees are based on the total number of sprinkler heads to be installed under the permitted plans, regardless of the number of risers involved. Additional heads that may be required at final inspection will be covered under the original permit, provided such heads do not exceed 5% of the total permitted amount, or an aggregate total of 10 heads, whichever is less.

A hydro visual test is required on all installations or relocations involving 20 or more heads. Tests shall be above 200 psi for two hours. Projects with less than 20 heads only require a final visual inspection. Pre-testing is required prior to requesting an inspection by the Fire Inspector. The alarm report will be requested to verify pre-testing.

Large fire sprinkler projects require a third-party review by a Fire Protection Engineer licensed in the State of Texas prior to submittal to our office. If uncertain about whether a third party review is needed, you may contact Scott Lingo at 817-276-4770 or scott.lingo@mansfieldtexas.gov

Approved plans shall be maintained on site at all times.