

Pre-Application Checklist: Copy of Contract ☐ Insurance Certificates ☐

Rose Valley Generator Permit Application

9 Old Mill Lane, Rose Valley, PA 19063

610-566-2044

Site Address _____ City _____

Type _____ Property Owner _____

Primary Contact _____ Phone _____ Email _____

Contractor _____ Address _____

Primary Contact _____ Phone _____ Email _____

What is the service gas pressure at this location _____ What size pipe will be used for the main gas run _____

What type of pipe will be used _____

What is the total developed length of the gas line for the generator _____

What type of transfer switch will be used _____ Will load shedding be provided _____

Installation Checklist

5' clearance to operable openings 10' to mechanical air intakes ☐

Manufacturer's clearances met. Typically 36" min. a side, but back can be 18" ☐

Non-combustible base provided ☐

Gas line enters/exits structure above grade ☐

Galvanized lines are not approved for direct burial ☐

Poly gas lines must be 18" below grade with a sand base and tracer wire ☐

Gas shut off at unit, and flexible connector with no bends provided ☐

Electrical load evaluated and generator sized by a qualified professional ☐

Gas line sized by a qualified professional, and service capacity approved by utility ☐

Description of Work _____

Applicant Signature _____ Date _____

Cost of Job Mechanical _____ Cost of Job Electrical _____

Municipal Comments:

Mech. Permit Fee _____ +\$4.50 Elec. Permit Fee _____ +4.50 Total Fee _____

3rd Party Signature _____ Date _____

All mechanical inspection requests or code questions should be directed to Linn Architects at inspections@rlinn.com or 610-566-7044 option 2. For the electrical inspection portion, call Dave at United Inspection Agency: 484-443-8895.