



**City of Banning
Riverside County Fire**
99 E. Ramsey Street • P.O. Box 998 •
Banning, CA 92220-0998 • (951) 922-4818



Fire Extinguishers/Smoke & Carbon Monoxide Alarm Certification of Compliance

The 2025 California Fire Code (CFC) and Health and Safety Code requires that Fire Extinguishers, Smoke and Carbon Monoxide alarms be installed and maintained in all residential dwelling units, apartment houses, lodging houses, etc.

Please refer to the California Fire Code and Health and Safety Code for all applicable requirements. The information below is a summary of common requirements. This form is an effort to ensure that smoke and carbon monoxide alarms are properly installed and maintained in an operating condition in all dwelling units and sleeping units.

Smoke Alarms

☐ In Compliance or ☐ Nonapplicable

A smoke alarm shall be located on the ceiling or wall outside of each separate sleeping area in the immediate vicinity of the bedrooms, in each room used for sleeping purposes, and in each story within the dwelling unit including basements. CFC 907.2.11, 1103.8. Health and Safety Code 13113.7

Carbon Monoxide Alarms

☐ In Compliance or ☐ Nonapplicable

Carbon Monoxide detection shall be provided in new and existing dwelling units and sleeping units that contain fuel burning appliances, fuel burning fireplaces, or fuel burning forced-air furnaces. Carbon Monoxide detection shall be installed in dwelling units outside of each separate sleeping area in the immediate vicinity of the bedrooms, on every occupiable level of a dwelling unit, including basements, or within a bedroom where a fuel-burning appliance is located or is served by a forced air furnace. **CFC 915.1, CFC 915.2, Health and Safety Code 17926.**

Ensure all new smoke and carbon monoxide alarms are approved and listed by the California Office of the State Fire Marshal. Current California law requires all smoke alarms to contain a nonreplaceable, nonremovable battery that is capable of powering the smoke alarm for at least 10 years. Please ensure that all devices purchased comply with California requirements. Information regarding approved and listed devices can be found at the Building Materials Listing Program found on www.osfm.fire.ca.gov.

Fire Extinguishers

☐ In Compliance or ☐ Nonapplicable

Fire extinguisher(s) are required to be installed as required by the California Fire Code Section 906. All fire extinguishers shall have a current service tag attached (within one year of the current date). The minimum size shall be 2-A:10-B:C with a minimum travel distance of 75 feet in public areas or 1-A:10B:C located in each dwelling unit and as otherwise required by code. **CFC 906.1**

AS THE OWNER OR AGENT FOR THE OWNER, THE UNDERSIGNED HEREBY CERTIFIES THAT THE DWELLING UNIT(S) LOCATED AT:

COMPLEX NAME & ADDRESS: _____ **Banning, CA 92220**

No of Units and Apartment or Hotel: _____

ARE EQUIPPED WITH PROPERLY INSTALLED AND OPERATING SMOKE AND CARBON MONOXIDE ALARMS AND FIRE EXTINGUISHERS AS REQUIRED.

SIGNATURE

TITLE

DATE

PRINT NAME

EMAIL

PHONE NUMBER

PLEASE FILL OUT AND MAIL BACK TO:

City of Banning, Office of the Fire Marshal, 99 E. Ramsey Street, Banning, CA 92220-0998