



City of Boerne Theatrical Fire Permit Request

Location:

Contact:

Contact #

Date(s) & Time(s) of Operation:

Special Requirements: *Open flame devices used in conjunction with theatrical performances are allowed to be used in accordance with NFPA 160 and the following conditions:*

- *Maintain safe distances (minimum of 10 feet) from spectators.*
- *Four or more fire extinguishers of the proper classification and size (minimum of 5 lb. units with current certifications) as approved by the authority having jurisdiction shall be readily accessible and located around the performance area, while the flame effects performance is being conducted.*
- *Standby fire safety personnel shall have a working knowledge of the supplemental fixed or portable fire-fighting equipment used in the area of the flame effects.*
- *The maximum quantity of flammable flame effect materials and loaded devices stored in a holding area separate from performance area shall be that quantity used in one day.*
- *At any time the theatrical performance may be stopped or halted by the fire code official or peace officer if it is deemed unsafe.*
- *Must be conducted outside any and all enclosed buildings and at a minimum of 10 feet from any building.*

Requested By:

**Fire Marshal's Office
City of Boerne**