



San Bruno Fire Department

Fire & Life Safety Division

555 El Camino Real · San Bruno, CA 94066 · (650) 616-7096 · fireprevention@sanbruno.ca.gov

Christmas Tree/ Pumpkin

Sales Permit

Please submit all completed permit applications to fireprevention@sanbruno.ca.gov
Permit applications shall be submitted at least 10 days prior to the opening. One-time permit only.

Name of Applicant: _____ License Number: _____

Phone Number: _____ Email: _____

Address of Tree Sales: _____

Proposed Date: _____ Time: _____ to _____

1. The San Bruno Fire & Life Safety Division shall be notified at least 48 hours prior to any inspections. Call (650) 616-7092 to schedule inspections.
2. Issuance of a permit is subject to compliance with the listed requirements and approval by field inspection and necessary tests.
3. I/we do absolve the San Bruno Fire Department, or any member thereof, of any and all liability for damage of any kind whatsoever that may occur as a result of this event.
4. Issuance of a permit is subject to proof of insurance with the City of San Bruno named as additional insured.
5. Licensed operator will conform to all requirements as contained in the California Code of Regulations.
6. An inspection of the event location, by the San Bruno Fire Department Fire & Life Safety Division, shall take place prior to the lot opening.
7. The San Bruno Fire Department will have the authority to supervise and inspect the event location prior to and during the event.

A site map shall be submitted and approved. Information to be included on the site map (to approximate scale):

1. All noise or music generating equipment shall cease operation at 10:00 pm.
2. Lighting shall face away from any adjacent residential area.
3. Property shall not be used in such a manner as to create a nuisance due to noise, crowding, dust, or other factors.
4. There shall be no open flame or burning of any type on the lot unless approved and permitted by the fire department.
5. There shall be at least one portable fire extinguisher of a Class 2A:10:BC type, currently serviced and accessible on the property. Extinguisher(s) shall be located within a maximum of seventy five feet (75') travel distance from any point in the area of the lot.
6. The property shall be restored to its original condition following its use under the permit.
7. Temporary lighting or electrical service may require an electrical permit. Once this application is approved, contact the San Bruno Building Departments to verify if a permit is needed. Call (650) 616-7074 or visit their office at 567 El Camino Real.
8. If a tent is to be erected, a tent permit shall be obtained from San Bruno Fire Department.
9. There shall not be any smoking in the area of the lot where Christmas trees are sold and stored. Signs shall be posted stating "No Smoking" and shall be lettered not less than four inches (4") in height on a contrasting color background.
10. Maintain central aisles of six feet (6') minimum width and tributary aisles of three feet (3') minimum width.
11. Proper placement of exit signs.

In affirming my signature hereon, I realize that as the permittee, I am responsible for compliance with all provisions under which this permit may be granted. Application or permit does not replace any license or permit required by any other agency.

Applicant's Signature: _____ Date: _____

Permit Authorized By: _____ Issue Date: _____